CABLE CAT.6A U/FTP LSZH – 23AWG – 700 MHZ - ATTESTATION OF CONFORMITY

Posted on 26-06-2024 by barpaadminuser

Attestation of Conformity

No. 2018-489

Cables for use in construction works
Reaction to fire class D_{ca}

Company
barpa
Rua Noé Pereira, 473
4510-706 Fânzeres
Portugal

Product description
Screened communication cable (U/FTP) with solid conductors, 4 twisted pairs, LSZH jacket

Product identification
Cable Cat. 6/6A U/FTP LSZH

Product references:
Cable Cat. 6 U/FTP LSZH; Part no. 82222222xxx
Cable Cat. 6A U/FTP LSZH; Part no. 82223222xxx
(xxx: coding for length)

Reaction to fire standards
- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2014

Reaction to fire classification
Class D_{ca}-s1,d2,a1

Technical report
T829378, DANAK-19/19241

EC Cabling product ID
6705

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 28 June 2018

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
certification.madebydelta.com