

CABLE CAT.6A U/UTP – LSZH – 23AWG - ATTESTATION OF CONFORMITY DCA

Posted on 26-06-2024 by barpaadminuser



Compliance Statement

No. 2025-458

Unscreened Permanent Link, Class E_A

Company

barpa
Rua Noé Pereira, 473
4510-706 Gondomar
Portugal

Permanent Link Identification (2 connector model)

Horizontal cable:

Cable Cat.6A U/UTP LSZH
Part no. 82223122MMM (M of Meters)

RJ45 connector for telecommunications outlet:

Keystone Jack RJ45 UTP Cat.6A Keystone 90 degrees
Part no. 8224311C090 (C: Colour)

RJ45 connector for patch panel:

Keystone Jack RJ45 UTP Cat.6A Keystone
Part no. 8224311C180 (C: Colour)

Patch Panel (mounting fixture):

Patch Panel 1U 24P (empty panel)
Part no. 82230101124

Wall outlet (mounting fixture):

Faceplate 45x45 for RJ45 keystone jack
Part no. 822501T000D (T: type, D: number of doors)

Generic cabling standards - Class E_A Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
 - EN 50173-1:2018 / EN 50173-2:2018
 - TIA-568.2-E:2024
- including all permanent link alien crosstalk parameters (PS ANEXT and PS AACR-F)

Technical report
12527305-04, DANAK-19/25110

EC Cabling product ID
7241

CS valid until
1 September 2026

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 5 August 2025

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager



FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com

