KEYSTONE – RJ45 CAT.6 – 90°/180° – UTP – 1.0 - COMPLIANCE STATEMENT

Posted on 27-06-2024 by barpaadminuser

FORCE Technology

Compliance Statement

No. 2026-1168

Unscreened Permanent Link, Class E

Company
barpa
Rua Noé Pereira, 473
4510-706 Gondomar
Portugal

Permanent Link Identification (2 connector model)

Horizontal cable:
barpa Cable Cat.6 U/UTP LSZH
Part no. 82222122MMM (M – of Meters)

RJ45 connector for telecommunications outlet and patch panel:
Keystone Jack RJ45 UTP Cat.6 Keystone; Part no. 8224211C180 (C: Colour)
Keystone Jack RJ45 UTP Cat.6 Keystone 90 degrees; Part no. 8224211C090 (C: Colour)

Including use with (mounting fixtures):
Patch panel: barpa Empty Patch Panel 1U 24P; Part no. 82230101124
Wall outlet: barpa Faceplate 45x45 for RJ45 keystone jack; Part no: 822501T000D
(T: Type, D: number of doors)

Generic cabling standards - Class E Permanent Link requirements
- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report	EC Cabling product ID	CS valid until
12626996-01, DANAK-19/26080	7377	1 September 2027

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 30 July 2026

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

EC VERIFIED

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com