

WHAT IS CPR?

Posted on 13-09-2021 by Rute Araújo



Categories: [Copper](#), [Fiber Optic](#)

The Construction Products Regulation (CPR), EU Regulation No 305/2011, lays down the harmonized conditions for the market of construction products. As a regulation to be applied throughout the European Single Market, it refers to the harmonized standards of CENELEC EN50575: 2014 and EN50575: 2014 / A1 which establish the criteria for the reaction to fire of electrical cables and telecommunications.

Any company that want to introduce Copper and Fiber cable in the European market should test, classify and label one product as the standard define. The CE marking is mandatory for all cables and cables assemblies that belongs to the fixed cabling installation.

PURPOSE

The main purposes of the CPR elaboration are the people and installations safety in case of fire, as well as the protection of the environment.

CPR came to create more transparency in the purchasing and selling products of construction used in buildings and projects of civil engineering. Any product that is intended to be permanently incorporated in construction works, subject to fire safety regulations, is considered to be a construction product.

WHY THE DENOMINATION LSZH IS NO LONGER ENOUGH?


In addition to the behavior of the cables during the combustion and potential propagation of the same combustion and release of dangerous substances, it was necessary to redefine methods of classification.

CPR adds criteria and test procedures to promote harmonized standards regarding to fire resistance.

WHICH ARE THE 7 EUROCLASSES?

	Euroclass (ca)	Classification Criteria	Additional Criteria	
No reaction	A	EN ISO 1716		
Very low	B1	EN 50399 Heat Release Flame spread	Smoke production (s1a, s1b, s2, s3) EN50399/EN61034-2	
Low	B2			
Small	C	EN 60332-1-2 Flame Propagation	Acidity (a1, a2, a3) EN 50267-2-3	
Improved	D			
Basic	E	EN 60332-1-2 Flame Propagation	Flaming Droplets (d0, d1, d2) EN 50399	
Undertermined	F			
				System 1+ - Initial type-testing - Continuous surveillance by Third-party certification bodys - Regular audit of production samples
				System 3 - Initial type-testing
				System 4 - Documents

The A and B1 class aren't applicable to data and networking cables.



WHO IS RESPONSIBLE?

Manufacturers :

- Ensure that all cables are tested and classified.
- Guarantee that the Declaration of Performance (DoP) is available for the buyer.
- Guarantee that the label is correctly identified.

Distributors:

- Ensure that the cable have all the necessary documents.
- Ensure that doesn't supply any cable that is outside the standard.
- Ensure that the cables that doesn't comply are removed from the market.
- Store and transport the cables making sure that doesn't affect the performance.

Specifiers:

- Declare in a transparente way the minimum class defined by the country. You should check the minimum standard for your country.


Installers:

- Ensure that all cables installed are correctly labeled and have the correct DoP.
- Ensure that all used cables comply to the minimum defined classes.

WHICH ARE THE ESSENTIAL DOCUMENTS?

- Declaration of Performance (DoP)

This is an official certificate which identifies the data of the manufacturer, the product, the responsible certifier, the performance and the Euroclass that the product complies with.

barpa CE	
Declaration of Performance N° 0030 <i>Declaração de Performance n° 0030</i>	
Code of the product: <i>Código do produto:</i>	82223I22**D1 (* - defines the length)
Type of product: <i>Tipo de produto:</i>	Lan Cables <i>Cabos de Rede</i>
Usage: <i>Usa Previsto:</i>	Cables for building installations under requirements of fire resistance. <i>Cabos para instalação em edifícios em que sejam exigida resistência a fogo.</i>
Manufacturer: <i>Fabricante:</i>	barpa Rua Noé Pereira, 473 4510-706 Fânzeres, Porto Portugal <i>info@barpa.eu</i>
Notified product certification body: <i>Organismo de Certificação do Produto:</i>	No. 0199 (Delta lab)
Harmonized Standard: <i>Norma Harmonizada:</i>	EN 5075:2014+A1:2016
Declared Performance: <i>Performance declarada:</i>	Dca s2,d2,at
Dangerous substance: <i>Substâncias perigosas:</i>	NDP (Not declared performance) NDP (Desempenho Não Declarado)
System: <i>Sistema:</i>	System 3 Sistema 3
<p>This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3. Signed for and on behalf of the manufacturer by Rute Araújo, barpa representative, 21.02.2019:</p>	
	
<small>• info@barpa.eu • Rua Noé Pereira, 473, 4510-706 Fânzeres, Portugal • www.barpa.eu</small>	

IN THE LABEL IS MANDATORY THIS INFORMATIONS:



- CE logo;
- Last two digits of the year that the product was certified;
- Factory data;
- Number of Declaration of Performance (DoP);
- Product code;
- Use of the product;
- Performance declared;
- Code of the lab.

In the cable should
say the Euroclass that
the product comply.

