

CERTIFICATE OF CONSTANCY OF PERFORMANCE

3130-CPR-075

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Cable type : FO Distribution / Drop Cable

Reaction to fire class : C_{ca}-s1a, d1, a1

Cables used in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

placed on the market under the name or trade mark of

barpa (ARGON LDA)

Rua Noé Pereira, No: 473, 4510-706 GONDOMAR / PORTUGAL

and produced in the manufacturing plant code:

837

EN 50575: 2014 + A1: 2016

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s) under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product .

This certificate was first issued on 23.03.2026 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ankara, 23.03.2026, Rev. 0



Technical Manager
Ersin Gök

PRODUCT DESCRIPTION:

Designation of cable family	FO Distribution / Drop Cable
Fiber count	2-24

RELEVANT CONSTRUCTIONAL INFORMATION:

Cable design	Tight Coated Fiber, Unfilled, Single Jacket
Single Tube / Multitube	Single tube
Sheath	Halogen Free Flame Retardant (HFFR) UV resistant
Armour	Does not include

ELECTRIC CABLES-EXTENDED APPLICATION OF TEST RESULTS FOR REACTION TO FIRE - EN 50576:

Fiber optic, 2-24 fibers

CABLE PARAMETER RANGE

$$\chi = 11$$

OUTER DIAMETER RANGE

$$D = 8,8 \text{ mm}$$



This is the Annex to the Certificate of Constancy of Performance No. 3130-CPR-075.